PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

No. 140 Date : 03/07/2024

It is certified that an inspection team headed by _____

PRAVEEM SHARMA (Name of Officers with designation) from N.N. PHE INDORE. (Name of Department/Office) inspected the THE VEDANSH INTERTNATIONAL SCHOOL at **Plot No. IGI-SP-01, Emaar Indore Greens, Super Corridor Extension, Village Nainod, Indore** (Name & Address of the School) on June 2024 and found that the THE VEDANSH INTERTNATIONAL SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of one year from the date of issue.

Signature with Seal : _____

Assistant Engineer
Maint Sub Dn. No. 3
IMC INDORE (M.P.)

Name : PRAVEEM SHARMA

Designation : Assitant Engineer

Assistant Engineer
Maint Sub Dn. No. 3
IMC. INDORE (M.P.)

To

THE VEDANSH INTERTNATIONAL SCHOOL

Plot No. IGI-SP-01, Emaar Indore Greens, Super Corridor Extension, Village Nainod ,Indore, M.P.

Mob. : 96179 80077
94250 77441
Ph. : 0731-2536017
2413864

Central Govt. Approved Laboratory for Agmark

Aavishkar Analytical Laboratory (Reg.)

50/1, Snehlataganj, Near Bank of Baroda, INDORE -452 003 (M.P.)
E-mail : aavishkarlab@gmail.com

Reg. No.3876/3/BPL/001 (Testing of Food as per Food Safety Standard and also Nutritional Value)

Name and address of customer :- The Vedansh International School Campus-2 Plot No. Igi-Sp-01, Emaar Indore Greens, Super Corridor Extension, Village Nainod, Indore.	Laboratory Reference Number (LRN)	:	AAL/13452
	Date Of Receipt	:	11/07/2026
	Condition , When Received	:	Satisfactory
	Packing , When Received	:	Packed
	Quantity Received (Approx.)	:	3 ltr.
	Date Of Start Test	:	11/07/2026
Sample identification : Water	Date Of Completion Of Test	:	15/07/2026
Sample particulars : RO Water			

TEST RESULT

S.NO.	TEST	RESULT	STANDARDS	TEST METHOD
1.	Appearance	Clear	Clear	IS 3025(PART4):2021
2.	Colour	Clear	Clear	IS 3025(PART4):2021
3.	Taste	Agreeable	Agreeable	IS 3025:1983(PART5)
4.	Odour	Agreeable	Agreeable	IS 3025: (PART8)
5.	PH	6.52	6.5 – 8.5	IS 3025(PART11):1983 REF.2002
6.	Turbidity	0.1	Not More Than 2 NTU	IS 3025:2017(Part 10)
7.	TDS	92 mg/lit	Not more than 500 mg/lit	IS 3025(PART16):2023
8.	Hardness As Calcium Carbonate	36 mg/lit	Max. - 200 mg/lit.	IS3025(PART21):2009SUBPART 5
9.	Calcium	15 mg /l	Max.75 mg/l	IS 3025(PART 40):1991REF.2019
10.	Magnesium	8.64mg/l	Max 30 mg/l	IS 3025(PART 32):19881REF.2019
11.	Suspended solid	Absent	Absent	IS3025(Part46):2023SubPart6
12.	Chloride	25 mg/l	Max.250 mg/l	IS3025(Part46):2023SubPart6
13.	Alkalinity	56 mg/l	Max. 120 mg/ l	IS 3025 (Part24) :2022

Continue....

Mob. : 96179 80077
94250 77441
Ph. : 0731-2536017
2413864

Central Govt. Approved Laboratory for Agmark

Aavishkar Analytical Laboratory (Reg.)

50/1, Snehlataganj, Near Bank of Baroda, INDORE -452 003 (M.P.)
E-mail : aavishkarlab@gmail.com

Reg. No.3876/3/BPL/001 (Testing of Food as per Food Safety Standard and also Nutritional Value)

Biological Testing

S.NO.	TEST	RESULT	STANDARDS	TEST METHOD
1.	E.Coli	Absent/100ml	Absent/100ml	IS 15185 : 2016
2.	Coliform	Absent/100ml	Absent/100ml	IS 15185 : 2016

*** END OF THE TEST REPORT***

Aavishkar Analytical Laboratory Chemist Incharge

Aavishkar Analytical Laboratory INDORE

Test Carried by/ Supervisor

Authorized Signatory/Issuing Authority

Note : 1.This Report in full or part may not be reproduced,published or used for any legal action unless,prior permission is secured from Director, Aavishkar analytical laboratory,indore.
2.Sample(s) are not drawn by us,unless otherwise stated.
3.The results relate to the items tested.
4. Sample will be stored only for 03 days by laboratory. After 03 days sample will be disposed of / destroyed by the laboratory.
5.This report is based solely on the sample provided and is valid only for the tested sample.
6.The laboratory is not responsible for the sample's origin or any consequences arising from its results.
7.This report is issued for the client only and not intended for third-party use without consent.
8. No responsibility is accepted for any action taken based on this report by any unauthorized party.
9.Results pertain only to the sample tested and are not indicative of the entire batch or product.
10.Partial reproduction of this report is prohibited without prior written permission.
11.This is a computer-generated report and does not require a physical sign
12. "This report is based solely on the sample provided and is valid only for the tested sample. The laboratory is not liable for its use by any third party."
13 Certain tects incuded in this report have been subcontracted to competent associated laboratories where the reauired testing facilities are not available in house.